

# REQUEST FOR PURCHASE IN EXCESS OF \$20,000/CHANGE ORDER



**To:** Mayor and Council

**Agenda Item #:** IV.J

**From:** Brian E. Olson, Director of Public Works *BEO*

**The Recommended Bid is**

Within Budget

Not Within Budget

**Date:** 2/19/2013

**Subject:** Emergency Repair Well 11, Public Works - Utilities

**Date Bid Opened or Quote Received:**  
02/05/2013

**Bid or Expiration Date:**  
2/05/2013

**Company:**  
E.H. Renner & Sons

**Amount of Quote or Bid:**  
\$ 27,151.25

**Recommended Quote or Bid:**  
E.H. Renner & Sons

## **General Information:**

Well 11 stopped working on February 1, 2013. During the week of February 4<sup>th</sup>, we asked E.H. Renner & Sons to diagnose the problem. We found that a section of the pump had failed and fell into the 403 foot well pit. There was significant wear on the column pipes and the 5 pump stages. Well No. 11 is a primary well for Edina's water supply and it pumps over 1 million gallons of water per day even during the winter months. We immediately ordered the parts necessary to put the pump back into service. Since this is an emergency repair, we are asking for approval of up to \$40,000 for any change order that could result from closer inspection of the parts.