



Edina Fire Department Responses - January 2014

Total Incidents = 381

SITUATION	DATE	ADDRESS	PROPERTY USE	CAUSE
Structure Fire	1/3/14	5100 block of Vernon Ave	Grocery store	Smoke reported in basement of Jerry's Foods. Fire in HVAC duct caused by malfunctioning fan motor.
	1/21/14	7500 block of Ikola Way	Ice Arena	Pop cooler in concession area of arena. Electrical malfunction caused sparks and flames. Extinguished by staff with dry chem extinguisher.
Cooking Fire, contained	1/3/14	6300 block of Ridgeview Dr	Single Family Dwelling	Malfunctioning electrical element in oven caught fire. Oven remained closed, no extension.
	1/5/14	5300 block of Vernon Ave	Multi-family Dwelling	Bacon grease fire. Lid contained fire, moved to sink & extinguished by resident with water.
Chimney Fire, contained	1/1/14	7200 block of Gloucester Dr	Single Family Dwelling	Creosote build-up caught fire. Gas insert in wood burning fire box.
Vehicle Fire	1/2/14	Highway 62 & France Ave	Highway	Engine fire.
	1/15/14	Highway 62 & France Ave	Highway	Engine fire.
Excessive heat, scorch burns w/ no ignition	1/3/14	4000 block of Parklawn Ave	Apt underground garage	Glowing electrical motor. Malfunction.
	1/14/14	4900 block of Sunnyslope Rd E	Single Family Dwelling	Child placed pillow against heated glass on gas fireplace. Pillow smoldered causing smoke, no ignition.
Assist Other Cities	1/10/14	6500 block of Newton Ave S	Richfield	Assist with salvage & overhaul.
	1/17/14	4500 block of 36 ½ St W	St Louis Park	Standby

1 Mutual Aid call was cancelled en route by each Bloomington Fire & Hopkins Fire

2 Mutual Aid calls were cancelled en route by Richfield Fire Dept.

Other calls for the month include:

289 Emergency Medical Service

6 Hazardous Conditions (Gas leaks, CO leaks, electrical arcing, etc.)

32 Service & Good Intent (Smoke scares, possible hazards w/o hazard, unauthorized burning, etc.)

39 False Fire Alarms 21 Commercial 18 Residential