



# Edina Fire Department Responses - January 2015

**Total Incidents = 418**

| SITUATION                      | DATE      | ADDRESS                   | PROPERTY USE           | CAUSE   |
|--------------------------------|-----------|---------------------------|------------------------|---|
| <b>Structure Fire</b>          | 1/1/15    | 5100 block of Lincoln Dr  | Multi-family dwelling  | Oven mitt accidentally touched to heating element, then put away in drawer not knowing it was smoldering. Smoldering mitt charred drawer and countertop. No flames. |
|                                | 1/13/15   | 4500 block of Laguna Dr   | Single family dwelling | Unattended heat gun thawing pipes. Radiated heat caught wood framing. Smoke detector alerted homeowner.   |
|                                | 1/16/2015 | 5000 block of Windsor Ave | Single family dwelling | Electrical malfunction near site of electrical meter.   |
| <b>Cooking Fire, contained</b> | 1/17/15   | 5800 block of Oaklawn Ave | Single family dwelling | Oven malfunction.   |
| <b>Vehicle Fire</b>            | 1/5/15    | Concord Ave & 58th St W   | Residential Street     | Engine fire.  |
| <b>Assist Other Cities</b>     | None      |                           |                        |   |

Other calls for the month include:

**343 Emergency Medical Service / Ambulance**

**2 Elevator Rescue**

**5 Hazardous Conditions** (Gas leaks, CO leaks, electrical arcing, etc.)

**29 Service & Good Intent** (Smoke scares, possible hazards w/o hazard, cancelled en route, unauthorized burning, etc.)

**34 False Alarms**

13 Commercial    21 Residential