



Edina Fire Department Responses - October 2015

Total Incidents = 413

SITUATION	DATE	ADDRESS	PROPERTY USE	CAUSE
Structure Fire	10/7/15	3500 block of W 70th St	Restaurant / Strip Mall	Natural gas bacon grill caught fire when no one there. Fire caught on security camera. Heat damaged area above grill, ceiling tiles and grill.
	10/23/15	5800 block of Zenith Ave S	Single Family dwelling	Likely cigarettes discarded in window planter boxes caught fire, damaged siding and window.
Cooking Fire, contained	10/14/15	7500 block of France Ave S	Restaurant / Strip Mall	Failed weld on hot box warmer allowed super heated air to exit and start plastic wire insulation on fire.
Brush/Grass Fire	10/10/2015	6600 block of Margarets La.	Wooded area	Caused by dumping fire pit ashes into yard waste in wooded area.
Dumpster Fire	10/21/15	5300 block of Edina Indust. Blvd.	Business	Fire in dumpster next to concrete building, glass on building broke due to heat. Dumpster filled with paint supplies. Unknown cause.
Special Outside Fire.	10/17/15	7200 block of York Ave S	Multi-family Dwelling	Planter box on deck had smoldering fire inside burning vegetation from carelessly discarded cigarettes.
Assist Other Cities	10/28/15	5100 block of American Blvd.	Bloomington/Hotel	Standby

Other calls for the month include:

308 Emergency Medical Service / Ambulance

10 Hazardous Conditions (Gas leaks, CO leaks, electrical arcing, etc.)

55 Service & Good Intent (Smoke scares, possible hazards w/o hazard, cancelled en route, unauthorized burning, etc.)

33 False Alarms

4 Medical Alarms

Malfunctions 2 Commercial 5 Residential 4 Multi-family

Unintentional 3 Commercial 7 Residential 8 Multi-family

(Cancelled en route: 1 Commercial 12 Residential 7 Multi-family)