



Edina Fire Department Responses

April 2012

SITUATION	DATE	ADDRESS	PROPERTY USE	CAUSE
Fires				
Structure Fire	4/6/12	7300 block of Ohms Ln	Business	Bathroom ceiling exhaust fan had malfunctioned, burned and fallen. Employee found fire out.
	4/6/12	7300 block of Gallagher Dr	Multi-family Dwelling	Resident pre-heating oven, plastic containers stored under oven caught fire.
	4/13/12	7100 block of York Av S	Multi-family Dwelling	Cigarette in ashtray was put in desk drawer, items in drawer caught fire. Plastic tubing carrying oxygen had been draped over drawer, also caught fire.
Cooking Fire, contained	4/2/12	4600 block of Oak Dr	Single Family Dwelling	Grease fire in oven, oven door locked due to high heat. Power and gas were disconnected to oven.
	4/21/12	5200 block of Lincoln Dr	Multi-family Dwelling	Oven fire during self cleaning cycle due to excess spilled food catching fire.
Natural Vegetation Fire	4/5/12	7700 block of York Av S	Business	Mulch in outdoor landscaping burning.
Outdoor Trash Fire	4/10/12	4100 block of Parklawn Av	Multi-family Dwelling	Fire in wall mounted cigarette disposal unit, contained.
Assist Other Cities	4/6/12	3900 block of Basswood Rd	Assist St Louis Park Fire Department	
		1 Mutual Aid call was cancelled en route by Richfield Fire Department		

Hazardous Conditions 9

Service & Good Intent
(Smoke scares, Hazmat w/ no hazmat, Unauthorized burning, etc.) 16

Emergency
Medical Service 292
Elevator Rescue 2

False Fire Alarms

Malicious Malfunctions 2 Residential
7 Commercial

Unintentional, Accidental 9 Residential
7 Commercial

Total 25

Total Incidents in April = 353